

SELECTION TABLES
End Suction Fire Pumps
60Hz Electric Motor Driven

Section 911.5 Page 301
 Date November 15, 2018
 Supersedes January 1, 2018

Flow	Pressure		Required Motor HP Rating			Maximum Shutoff (PSI)*	Pump Model
	PSI	Feet	Motor HP	Speed (RPM)	Horsepower (BHP)		
50 GPM	41	95	5	1770	5.2	42	2.5-384-13.5
	45	104	10	1770	9.3	46	2.5-384-13.5
	50	116	15	1770	16	51	2.5-384-13.5
	55	127	15	1770	18	56	2.5-384-13.5
	60	139	20	1770	19	62	2.5-384-13.5
	65	150	20	1770	21	67	2.5-384-13.5
	70	162	20	1770	22	72	2.5-384-13.5
	75	173	25	1770	24	77	2.5-384-13.5
	80	185	25	1770	26	83	2.5-384-13.5
	82	189	25	1770	27	84	2.5-384-13.5
84	194	25	1770	28	87	2.5-384-13.5	

100 GPM	41	95	7.5	1770	6.7	43	2.5-384-13.5
			7.5	3560	7.8	42	2.5-384-7
	45	104	10	1770	9.4	47	2.5-384-13.5
			7.5	3560	8.4	46	2.5-384-7
	47	109	15	1770	16	48	3-384-11
	50	116	15	1770	16	52	2.5-384-13.5
			20	1770	18	51	3-384-11
			10	3560	9.3	51	2.5-384-7
	55	127	20	1770	21	56	3-384-11
			15	1770	18	57	2.5-384-13.5
			20	1770	22	56	3-384-11
			15	3560	14	56	2.5-384-7
	60	139	20	1770	19	62	2.5-384-13.5
			15	3560	16	61	2.5-384-7
	65	150	20	1770	21	68	2.5-384-13.5
			15	3560	17	66	2.5-384-7
	70	162	20	1770	23	73	2.5-384-13.5
			20	3560	19	71	2.5-384-7
	75	173	25	1770	24	78	2.5-384-13.5
			20	3560	20	76	2.5-384-7
80	185	25	1770	26	83	2.5-384-13.5	
		20	3560	22	82	2.5-384-7	
81	187	25	1770	27	84	2.5-384-13.5	
83	192	25	1770	28	87	2.5-384-13.5	
85	196	25	3560	24	87	2.5-384-7	
87	201	25	3560	24	89	2.5-384-7	

*Maximum shutoff includes Hydraulic Institute's tolerance of 6%. Value is used to determine flange rating for the pump.



SELECTION TABLES
End Suction Fire Pumps
60Hz Electric Motor Driven

Section 911.5 Page 302
 Date November 15, 2018
 Supersedes January 1, 2018

Flow	Pressure		Required Motor HP Rating			Maximum Shutoff (PSI)*	Pump Model
	PSI	Feet	Motor HP	Speed (RPM)	Horsepower (BHP)		
150 GPM	41	95	7.5	1770	8.4	44	2.5-384-13.5
	43	99	15	1770	15	44	3-384-13.5
	45	104	10	1770	9.7	48	2.5-384-13.5
			15	1770	16	46	3-384-13.5
	47	109	15	1770	16	48	3-384-11
			15	1770	16	53	2.5-384-13.5
	50	116	20	1770	18	51	3-384-11
			20	1770	18	51	3-384-13.5
			15	3560	13	53	2.5-384-7
	55	127	20	1770	18	58	2.5-384-13.5
			20	1770	21	57	3-384-11
			20	1770	20	56	3-384-13.5
			15	3560	14	57	2.5-384-7
			25	3560	28	56	4-384-7
	60	139	20	1770	20	63	2.5-384-13.5
			20	1770	23	62	3-384-13.5
			15	3560	16	62	2.5-384-7
			30	3560	31	61	4-384-7
	65	150	20	1770	21	69	2.5-384-13.5
			25	1770	25	67	3-384-13.5
			15	3560	17	67	2.5-384-7
			30	3560	34	66	4-384-7
	70	162	20	1770	23	74	2.5-384-13.5
			25	1770	27	72	3-384-13.5
			20	3560	19	72	2.5-384-7
			40	3560	38	71	4-384-7
	75	173	25	1770	25	79	2.5-384-13.5
			30	1770	30	77	3-384-13.5
			20	3560	21	77	2.5-384-7
			40	3560	41	76	4-384-7
	78	180	30	1770	31	81	3-384-13.5
	79	182	30	1770	32	82	3-384-13.5
80	185	25	1770	27	84	2.5-384-13.5	
		25	1770	27	85	2.5-384-13.5	
		20	3560	22	82	2.5-384-7	
		40	3560	45	82	4-384-7	
82	189	25	1770	28	87	2.5-384-13.5	
84	193	30	3560	35	85	4-384-7	
85	196	25	3560	24	87	2.5-384-7	
		50	3560	49	87	4-384-7	
87	200	25	3560	24	89	2.5-384-7	
		25	3560	24	89	2.5-384-7	
90	208	50	3560	51	92	4-384-7	
92	213	50	3560	51	94	4-384-7	

*Maximum shutoff includes Hydraulic Institute's tolerance of 6%. Value is used to determine flange rating for the pump.



SELECTION TABLES
End Suction Fire Pumps
60Hz Electric Motor Driven

Section 911.5 Page 303
 Date November 15, 2018
 Supersedes January 1, 2018

Flow	Pressure		Required Motor HP Rating			Maximum Shutoff (PSI)*	Pump Model
	PSI	Feet	Motor HP	Speed (RPM)	Horsepower (BHP)		
200 GPM	43	99	15	1770	15	44	3-384-13.5
	45	104	15	1770	16	46	3-384-13.5
	46	106	15	1770	16	47	3-384-11
	49	113	15	1770	17	54	2.5-384-13.5
			15	3560	13	53	2.5-384-7
	50	116	15	1770	17	55	2.5-384-13.5
			20	1770	19	52	3-384-11
			20	1770	18	52	3-384-13.5
			15	3560	14	54	2.5-384-7
	54	125	25	3560	27	55	4-384-7
			20	1770	21	56	3-384-11
	55	127	20	1770	19	60	2.5-384-13.5
			20	1770	21	57	3-384-11
			20	1770	21	57	3-384-13.5
			15	3560	15	59	2.5-384-7
			25	3560	28	56	4-384-7
	60	139	20	1770	20	65	2.5-384-13.5
			20	1770	23	62	3-384-13.5
			15	3560	16	64	2.5-384-7
			30	3560	31	61	4-384-7
	65	150	20	1770	22	70	2.5-384-13.5
			25	1770	25	67	3-384-13.5
			20	3560	18	69	2.5-384-7
			30	3560	35	66	4-384-7
	70	162	20	1770	23	75	2.5-384-13.5
			25	1770	27	73	3-384-13.5
			20	3560	19	74	2.5-384-7
			40	3560	38	71	4-384-7
	75	173	25	1770	25	81	2.5-384-13.5
			30	1770	30	78	3-384-13.5
			20	3560	21	78	2.5-384-7
			40	3560	41	77	4-384-7
	78	179	30	1770	31	81	3-384-13.5
			30	1770	31	81	3-384-13.5
	79	182	25	1770	27	84	2.5-384-13.5
	80	185	25	1770	27	86	2.5-384-13.5
			20	3560	23	83	2.5-384-7
			40	3560	45	82	4-384-7
	81	187	25	1770	28	87	2.5-384-13.5
	83	193	40	3560	36	85	4-384-7
85	196	25	3560	24	88	2.5-384-7	
		50	3560	49	87	4-384-7	
		25	3560	24	89	2.5-384-7	
86	199	25	3560	24	89	2.5-384-7	
90	208	50	3560	51	92	4-384-7	
91	210	50	3560	51	93	4-384-7	

*Maximum shutoff includes Hydraulic Institute's tolerance of 6%. Value is used to determine flange rating for the pump.



SELECTION TABLES
End Suction Fire Pumps
60Hz Electric Motor Driven

Flow	Pressure		Required Motor HP Rating			Maximum Shutoff (PSI)*	Pump Model
			Motor HP	Speed (RPM)	Horsepower (BHP)		
	PSI	Feet					
250 GPM	42	97	15	1770	15	44	3-384-13.5
	45	104	15	1770	17	47	3-384-13.5
	46	106	15	1770	16	48	3-384-11
			15	3560	13	53	2.5-384-7
	47	109	15	1770	17	54	2.5-384-13.5
			15	1770	18	57	2.5-384-13.5
	50	116	20	1770	19	52	3-384-11
			20	1770	19	52	3-384-13.5
			15	3560	14	57	2.5-384-7
	54	125	20	1770	21	56	3-384-11
			25	3560	28	55	4-384-7
	55	127	20	1770	19	62	2.5-384-13.5
			20	1770	21	58	3-384-13.5
			15	3560	16	62	2.5-384-7
			25	3560	28	56	4-384-7
	60	139	20	1770	21	67	2.5-384-13.5
			20	1770	23	63	3-384-13.5
			15	3560	17	66	2.5-384-7
	65	150	30	3560	31	61	4-384-7
			20	1770	22	72	2.5-384-13.5
			25	1770	25	68	3-384-13.5
			20	3560	19	71	2.5-384-7
	70	162	30	3560	35	67	4-384-7
			25	1770	24	77	2.5-384-13.5
			25	1770	28	73	3-384-13.5
	75	173	20	3560	20	75	2.5-384-7
			40	3560	38	72	4-384-7
			25	1770	26	82	2.5-384-13.5
			30	1770	30	78	3-384-13.5
	77	178	20	3560	22	80	2.5-384-7
			40	3560	42	77	4-384-7
			30	1770	31	81	3-384-13.5
	78	180	25	1770	27	84	2.5-384-13.5
			30	1770	32	81	3-384-13.5
	79	182	25	1770	27	86	2.5-384-13.5
	80	185	20	3560	23	85	2.5-384-7
			40	3560	45	82	4-384-7
	83	192	40	3560	38	85	4-384-7
	84	194	25	3560	24	89	2.5-384-7
			25	3560	24	89	2.5-384-7
	85	196	50	3560	49	87	4-384-7
	88	203	60	3560	60	93	4-384-9.5
90	208	50	3560	51	92	4-384-7	
		60	3560	62	95	4-384-9.5	
91	210	50	3560	51	93	4-384-7	
95	219	60	3560	66	100	4-384-9.5	
100	231	75	3560	70	105	4-384-9.5	
105	243	75	3560	74	110	4-384-9.5	
110	254	75	3560	79	115	4-384-9.5	
111	256	50	3560	56	116	3-384-11	
115	266	60	3560	58	120	3-384-11	
		75	3560	83	121	4-384-9.5	
120	277	60	3560	62	125	3-384-11	
		100	3560	87	126	4-384-9.5	
125	289	60	3560	65	130	3-384-11	
		100	3560	92	131	4-384-9.5	

*Maximum shutoff includes Hydraulic Institute's tolerance of 6%. Value is used to determine flange rating for the pump.



**SELECTION TABLES
End Suction Fire Pumps
60Hz Electric Motor Driven**

Section 911.5 Page 305
Date November 15, 2018
Supersedes January 1, 2018

Flow	Pressure		Required Motor HP Rating			Maximum Shutoff (PSI)*	Pump Model
	PSI	Feet	Motor HP	Speed (RPM)	Horsepower (BHP)		
250 GPM	130	300	60	3560	68	135	3-384-11
			100	3560	97	136	4-384-9.5
	135	312	75	3560	72	140	3-384-11
			100	3560	101	141	4-384-9.5
	140	323	75	3560	75	145	3-384-11
			100	3560	106	146	4-384-9.5
	145	335	75	3560	78	150	3-384-11
			100	3560	111	151	4-384-9.5
	150	347	75	3560	82	154	3-384-11
			125	3560	116	156	4-384-9.5
	155	358	75	3560	85	159	3-384-11
			125	3560	121	162	4-384-9.5
	160	370	100	3560	89	164	3-384-11
			125	3560	124	167	4-384-9.5
	161	373	125	3560	124	168	4-384-9.5
	162	374	125	3560	125	169	4-384-9.5
	165	381	100	3560	92	169	3-384-11
	170	393	100	3560	96	174	3-384-11
	175	404	100	3560	100	179	3-384-11
	180	416	100	3560	103	184	3-384-11
185	427	100	3560	107	189	3-384-11	
190	439	100	3560	111	194	3-384-11	
195	450	100	3560	115	199	3-384-11	
200	462	125	3560	118	204	3-384-11	
205	474	125	3560	122	209	3-384-11	
210	485	125	3560	123	214	3-384-11	
213	492	125	3560	126	217	3-384-11	
214	494	125	3560	126	218	3-384-11	

*Maximum shutoff includes Hydraulic Institute's tolerance of 6%. Value is used to determine flange rating for the pump.



SELECTION TABLES
End Suction Fire Pumps
60Hz Electric Motor Driven

Section 911.5 Page 306
 Date November 15, 2018
 Supersedes January 1, 2018

Flow	Pressure		Required Motor HP Rating			Maximum Shutoff (PSI)*	Pump Model
	PSI	Feet	Motor HP	Speed (RPM)	Horsepower (BHP)		
300 GPM	41	95	15	1770	15	44	3-384-13.5
	44	102	15	1770	17	54	2.5-384-13.5
	45	104	15	1770	17	55	2.5-384-13.5
			15	1770	16	48	3-384-11
			15	1770	17	48	3-384-13.5
	50	116	20	1770	19	60	2.5-384-13.5
			20	1770	20	53	3-384-11
			20	1770	19	53	3-384-13.5
	53	123	20	1770	21	56	3-384-11
	54	125	20	1770	21	57	3-384-11
			25	3560	28	56	4-384-7
	55	127	20	1770	20	65	2.5-384-13.5
			20	1770	21	59	3-384-13.5
			25	3560	28	57	4-384-7
	60	139	20	1770	21	69	2.5-384-13.5
			25	1770	24	64	3-384-13.5
			30	3560	32	62	4-384-7
	65	150	20	1770	23	74	2.5-384-13.5
			25	1770	26	69	3-384-13.5
			40	3560	35	67	4-384-7
	70	162	25	1770	25	79	2.5-384-13.5
			25	1770	28	74	3-384-13.5
			40	3560	38	72	4-384-7
	75	173	25	1770	26	84	2.5-384-13.5
			30	1770	30	79	3-384-13.5
			40	3560	42	77	4-384-7
			25	1770	27	84	2.5-384-13.5
	77	177	30	1770	31	81	3-384-13.5
			25	1770	27	86	2.5-384-13.5
			30	1770	31	81	3-384-13.5
	80	185	40	3560	46	82	4-384-7
	83	192	40	3560	39	85	4-384-7
	85	196	50	3560	49	87	4-384-7
	88	203	60	3560	60	93	4-384-9.5
	90	208	50	3560	51	92	4-384-7
			60	3560	62	95	4-384-9.5
91	210	50	3560	51	93	4-384-7	
95	219	60	3560	66	100	4-384-9.5	
100	231	75	3560	70	106	4-384-9.5	
105	243	75	3560	75	111	4-384-9.5	
110	254	50	3560	56	116	3-384-11	
		50	3560	56	116	3-384-11	
		75	3560	79	116	4-384-9.5	
115	266	60	3560	59	121	3-384-11	
		75	3560	83	121	4-384-9.5	
120	277	60	3560	62	126	3-384-11	
		100	3560	88	126	4-384-9.5	
125	289	60	3560	65	131	3-384-11	
		100	3560	92	131	4-384-9.5	
130	300	60	3560	69	136	3-384-11	
		100	3560	97	136	4-384-9.5	
135	312	75	3560	72	140	3-384-11	
		100	3560	102	142	4-384-9.5	
140	323	75	3560	75	145	3-384-11	
		100	3560	106	147	4-384-9.5	

*Maximum shutoff includes Hydraulic Institute's tolerance of 6%. Value is used to determine flange rating for the pump.



**SELECTION TABLES
End Suction Fire Pumps
60Hz Electric Motor Driven**

Section 911.5 Page 307
Date November 15, 2018
Supersedes January 1, 2018

Flow	Pressure		Required Motor HP Rating			Maximum Shutoff (PSI)*	Pump Model
	PSI	Feet	Motor HP	Speed (RPM)	Horsepower (BHP)		
3 0 0 G P M	145	335	75	3560	79	150	3-384-11
			100	3560	111	152	4-384-9.5
	150	347	75	3560	82	155	3-384-11
			125	3560	116	157	4-384-9.5
	155	358	75	3560	86	160	3-384-11
			125	3560	121	162	4-384-9.5
	160	370	100	3560	89	165	3-384-11
			125	3560	124	167	4-384-9.5
	161	371	125	3560	124	168	4-384-9.5
	162	374	125	3560	125	169	4-384-9.5
	165	381	100	3560	93	170	3-384-11
	170	393	100	3560	96	175	3-384-11
	175	404	100	3560	100	180	3-384-11
	180	416	100	3560	104	184	3-384-11
	185	427	100	3560	107	189	3-384-11
	190	439	100	3560	111	194	3-384-11
	195	450	100	3560	115	199	3-384-11
	200	462	125	3560	119	204	3-384-11
205	474	125	3560	123	209	3-384-11	
210	485	125	3560	124	214	3-384-11	
212	491	125	3560	126	217	3-384-11	
214	494	125	3560	126	218	3-384-11	

*Maximum shutoff includes Hydraulic Institute's tolerance of 6%. Value is used to determine flange rating for the pump.



SELECTION TABLES
End Suction Fire Pumps
60Hz Electric Motor Driven

Section 911.5 Page 308
 Date November 15, 2018
 Supersedes January 1, 2018

Flow	Pressure		Required Motor HP Rating			Maximum Shutoff (PSI)*	Pump Model
	PSI	Feet	Motor HP	Speed (RPM)	Horsepower (BHP)		
400 GPM	42	97	15	1770	16	48	3-384-11
	45	104	20	1770	18	51	3-384-11
	50	116	20	1770	21	55	3-384-11
	51	118	20	1770	21	56	3-384-11
	52	120	20	1770	21	57	3-384-11
			25	3560	27	55	4-384-7
	55	127	30	3560	29	58	4-384-7
	60	139	30	3560	33	63	4-384-7
	65	150	40	3560	36	68	4-384-7
	70	162	40	3560	39	73	4-384-7
	75	173	40	3560	43	78	4-384-7
	80	185	40	3560	46	83	4-384-7
	82	190	40	3560	43	85	4-384-7
	85	196	50	3560	50	88	4-384-7
	87	201	60	3560	60	93	4-384-9.5
	90	208	50	3560	51	93	4-384-7
			60	3560	63	96	4-384-9.5
	95	219	60	3560	67	101	4-384-9.5
	100	231	75	3560	71	107	4-384-9.5
	105	243	75	3560	76	112	4-384-9.5
	108	249	50	3560	56	116	3-384-11
	110	254	50	3560	57	118	3-384-11
			75	3560	80	117	4-384-9.5
	115	266	60	3560	60	123	3-384-11
			75	3560	84	122	4-384-9.5
	120	277	60	3560	63	128	3-384-11
			100	3560	89	127	4-384-9.5
	125	289	60	3560	67	133	3-384-11
			100	3560	93	132	4-384-9.5
	130	300	75	3560	70	138	3-384-11
			100	3560	98	138	4-384-9.5
	135	312	75	3560	73	142	3-384-11
			100	3560	103	143	4-384-9.5
	140	323	75	3560	77	147	3-384-11
			100	3560	108	148	4-384-9.5
	145	335	75	3560	80	152	3-384-11
			100	3560	112	153	4-384-9.5
	150	347	75	3560	83	157	3-384-11
			125	3560	117	158	4-384-9.5
	155	358	100	3560	87	162	3-384-11
			125	3560	122	163	4-384-9.5
	160	369	125	3560	124	168	4-384-9.5
100			3560	90	167	3-384-11	
125			3560	124	168	4-384-9.5	
161	372	125	3560	126	170	4-384-9.5	
165	381	100	3560	94	171	3-384-11	
170	393	100	3560	98	176	3-384-11	
175	404	100	3560	101	181	3-384-11	
180	416	100	3560	105	186	3-384-11	
185	427	100	3560	109	191	3-384-11	
190	439	100	3560	112	196	3-384-11	
195	450	125	3560	116	201	3-384-11	
200	462	125	3560	120	205	3-384-11	
205	474	125	3560	124	210	3-384-11	
210	485	125	3560	125	215	3-384-11	
211	488	125	3560	126	217	3-384-11	
213	492	125	3560	126	218	3-384-11	

*Maximum shutoff includes Hydraulic Institute's tolerance of 6%. Value is used to determine flange rating for the pump.



SELECTION TABLES
End Suction Fire Pumps
60Hz Electric Motor Driven

Section 911.5 Page 309
 Date November 15, 2018
 Supersedes January 1, 2018

Flow	Pressure		Required Motor HP Rating			Maximum Shutoff (PSI)*	Pump Model
			Motor HP	Speed (RPM)	Horsepower (BHP)		
	PSI	Feet					
450 GPM	40	92	15	1770	16	48	3-384-11
	45	104	20	1770	19	52	3-384-11
	50	115	20	1770	21	56	3-384-11
			20	1770	21	57	3-384-11
	51	118	25	3560	27	55	4-384-7
	55	127	30	3560	30	59	4-384-7
	60	139	30	3560	33	64	4-384-7
	65	150	40	3560	36	69	4-384-7
	70	162	40	3560	40	74	4-384-7
	75	173	40	3560	43	79	4-384-7
	80	185	50	3560	47	84	4-384-7
	82	189	40	3560	44	85	4-384-7
	85	196	50	3560	50	89	4-384-7
	86	199	60	3560	60	93	4-384-9.5
			50	3560	51	94	4-384-7
	90	208	60	3560	63	97	4-384-9.5
			60	3560	68	102	4-384-9.5
	95	219	60	3560	68	102	4-384-9.5
	100	231	75	3560	72	107	4-384-9.5
	105	243	75	3560	76	112	4-384-9.5
	106	245	50	3560	55	115	3-384-11
	110	254	50	3560	58	119	3-384-11
			75	3560	80	118	4-384-9.5
	115	266	60	3560	61	124	3-384-11
			75	3560	85	123	4-384-9.5
	120	277	60	3560	64	129	3-384-11
			100	3560	89	128	4-384-9.5
	125	289	60	3560	68	134	3-384-11
			100	3560	94	133	4-384-9.5
	130	300	75	3560	71	139	3-384-11
			100	3560	99	138	4-384-9.5
	135	312	75	3560	74	144	3-384-11
			100	3560	103	143	4-384-9.5
	140	323	75	3560	78	149	3-384-11
100			3560	108	148	4-384-9.5	
145	335	75	3560	81	153	3-384-11	
		100	3560	113	154	4-384-9.5	
150	347	75	3560	84	158	3-384-11	
		125	3560	118	159	4-384-9.5	
155	358	100	3560	88	163	3-384-11	
		125	3560	123	164	4-384-9.5	
159	367	125	3560	124	168	4-384-9.5	
160	370	100	3560	91	168	3-384-11	
		125	3560	124	169	4-384-9.5	
165	381	100	3560	95	172	3-384-11	
170	393	100	3560	98	177	3-384-11	
175	404	100	3560	102	182	3-384-11	
180	416	100	3560	106	187	3-384-11	
185	427	100	3560	109	192	3-384-11	
190	439	100	3560	113	196	3-384-11	
195	450	125	3560	117	201	3-384-11	
200	462	125	3560	121	206	3-384-11	
205	474	125	3560	124	211	3-384-11	
210	486	125	3560	126	217	3-384-11	
212	490	125	3560	126	218	3-384-11	

*Maximum shutoff includes Hydraulic Institute's tolerance of 6%. Value is used to determine flange rating for the pump.



SELECTION TABLES
End Suction Fire Pumps
60Hz Electric Motor Driven

Section 911.5 Page 310
 Date November 15, 2018
 Supersedes January 1, 2018

Flow	Pressure		Required Motor HP Rating			Maximum Shutoff (PSI)*	Pump Model
	PSI	Feet	Motor HP	Speed (RPM)	Horsepower (BHP)		
500 GPM	50	116	25	3560	27	55	4-384-7
	55	127	30	3560	31	60	4-384-7
	60	139	30	3560	34	65	4-384-7
	65	150	40	3560	37	70	4-384-7
	70	162	40	3560	40	75	4-384-7
	75	173	40	3560	44	80	4-384-7
	80	185	50	3560	47	85	4-384-7
	81	187	50	3560	48	88	4-384-7
	85	196	50	3560	51	89	4-384-7
	86	199	60	3560	61	95	4-384-9.5
	89	206	50	3560	51	94	4-384-7
	90	208	60	3560	64	99	4-384-9.5
	95	219	60	3560	68	104	4-384-9.5
	100	231	75	3560	72	109	4-384-9.5
	105	243	50	3560	56	116	3-384-11
			75	3560	77	114	4-384-9.5
	110	254	60	3560	59	121	3-384-11
			75	3560	81	119	4-384-9.5
	115	266	60	3560	62	126	3-384-11
			75	3560	86	124	4-384-9.5
	120	277	60	3560	65	131	3-384-11
			100	3560	90	130	4-384-9.5
	125	289	60	3560	69	136	3-384-11
			100	3560	95	135	4-384-9.5
	130	300	75	3560	72	140	3-384-11
			100	3560	99	140	4-384-9.5
	135	312	75	3560	75	145	3-384-11
			100	3560	104	145	4-384-9.5
	140	323	75	3560	79	150	3-384-11
			100	3560	109	150	4-384-9.5
	145	335	75	3560	82	155	3-384-11
			100	3560	114	155	4-384-9.5
	150	347	75	3560	85	159	3-384-11
			125	3560	119	161	4-384-9.5
	155	358	100	3560	89	164	3-384-11
			125	3560	124	166	4-384-9.5
	158	366	125	3560	124	169	4-384-9.5
	159	367	125	3560	125	170	4-384-9.5
	160	370	100	3560	92	169	3-384-11
	165	381	100	3560	96	174	3-384-11
	170	393	100	3560	99	178	3-384-11
175	404	100	3560	103	183	3-384-11	
180	416	100	3560	106	188	3-384-11	
185	427	100	3560	110	193	3-384-11	
190	439	100	3560	114	198	3-384-11	
195	450	125	3560	118	202	3-384-11	
200	462	125	3560	121	207	3-384-11	
205	474	125	3560	125	212	3-384-11	
209	483	125	3560	126	217	3-384-11	
210	485	125	3560	126	217	3-384-11	
211	487	125	3560	127	218	3-384-11	

*Maximum shutoff includes Hydraulic Institute's tolerance of 6%. Value is used to determine flange rating for the pump.



**SELECTION TABLES
End Suction Fire Pumps
60Hz Electric Motor Driven**

Section 911.5 Page 311
Date November 15, 2018
Supersedes January 1, 2018

Flow	Pressure		Required Motor HP Rating			Maximum Shutoff (PSI)*	Pump Model
			Motor HP	Speed (RPM)	Horsepower (BHP)		
	PSI	Feet					
7 5 0 G P M	81	187	60	3560	60	93	4-384-9.5
	85	196	60	3560	64	98	4-384-9.5
	90	208	60	3560	68	103	4-384-9.5
	95	219	75	3560	72	108	4-384-9.5
	100	231	75	3560	76	113	4-384-9.5
	105	243	75	3560	81	118	4-384-9.5
	110	254	75	3560	85	123	4-384-9.5
	115	266	100	3560	90	128	4-384-9.5
	120	277	100	3560	94	133	4-384-9.5
	125	289	100	3560	99	138	4-384-9.5
	130	300	100	3560	104	143	4-384-9.5
	135	312	100	3560	108	148	4-384-9.5
	140	323	100	3560	113	154	4-384-9.5
	145	335	125	3560	118	159	4-384-9.5
	150	347	125	3560	123	164	4-384-9.5
	154	356	125	3560	124	169	4-384-9.5
155	358	125	3560	124	169	4-384-9.5	

*Maximum shutoff includes Hydraulic Institute's tolerance of 6%. Value is used to determine flange rating for the pump.

